

830 UTILITY CARRIER CABINETS

830.01 STANDARDS

Utility carrier cabinets shall comply with the following standards:

- A. Maximum Volume: Unless approved pursuant to Section 1203, *Conditional Uses*, the maximum combined volume of all utility carrier cabinets located on a single lot shall be:
 - 1. Forty cubic feet in a residential or OSM zoning district inside the Portland Metropolitan Urban Growth Boundary (UGB);
 - 2. Two hundred cubic feet in a commercial or industrial zoning district inside the UGB; and
 - 3. Two hundred fifty cubic feet outside the UGB..
- B. Maximum Height: The maximum height shall be five feet.
- C. Setback Exemption: Utility carrier cabinets are exempt from the minimum setback standards of this Ordinance.
- D. Contact Information: Utility companies shall clearly identify their carrier cabinets and provide an emergency telephone number where accidents or public safety concerns may be reported.
- E. Design, Screening, or Landscaping: Within the Portland Metropolitan Urban Growth Boundary, utility carrier cabinets shall be designed, screened, or landscaped to blend with the development on the same lot of record or, if the utility carrier cabinet is in the right-of-way, with the development on the lot of record nearest the cabinet.

[Amended by Ord. ZDO-224, 5/31/11; Amended by Ord. ZDO-248, 10/13/14; Amended by Ord. ZDO-268, 10/2/18]