



INVITATION TO BID #2018-09
McLoughlin Blvd Street Lighting Project (“BID”)
RESPONSE TO CLARIFYING QUESTIONS
February 26, 2018

Note that the following is a question submitted by an interested firm to the above referenced solicitation. The below answer is for clarification purposes only and in no way alter or amend the BID as published.

- 1. Is the Contractor to install a ground rod at each light pole foundation per PGE spec or will PGE install it when they put on the pole?*

Answer: The issued specs indicate that the ground rods are to be installed by the contractor.

End of Clarifying Questions #1