



GEORGE MARLTON, JD  
PROCUREMENT DIVISION DIRECTOR

PROCUREMENT DIVISION  
PUBLIC SERVICES BUILDING  
2051 KAEN ROAD | OREGON CITY, OR 97045

REQUEST FOR QUOTES #2018-126  
BARTON PARK MAIN WATER LINE REPLACEMENT-PHASE 1  
RESPONSE TO CLARIFYING QUESTIONS #1  
January 15, 2019

Note that these are questions submitted by interested firms to the above referenced solicitation. The below answers are for clarification purposes only and in no way alter or amend the RFQ as published.

1. *What diameter is the pipe to be replaced and what is the material?*

**Answer:** The main lines (A&C) are 2-1/2" PVC, however the feeder line (D) is 2" PVC. This is based on what can be seen at inlets and valve box, and doesn't mean that there isn't an underground section somewhere where the pipe is smaller or larger from a previous repair or work.

---

End of Clarifying Questions #1