



**ACTIONS TAKEN AT LAND USE PUBLIC HEARING
HELD July 25, 2024**

Please direct all calls and correspondence to the staff contact indicated below.

Hearing Time: 1:00 p.m.

File Number: Z0161-24

Proposal: The applicant proposes to construct a municipal water storage reservoir. The reservoir will be a green, bolted steel tank, with an aluminum dome top. They are seeking review of two possible sizes: A 500,000-gallon reservoir would be approximately 61-feet in diameter and 28 feet tall; alternatively, a 1,000,000-gallon reservoir would be approximately 81-feet in diameter and 30 feet tall. Whichever size reservoir is selected, the tank will be located in the northwest corner of the property abutting along SE Lucky Ln.

Staff contact: Melissa Lord; 503-742-4504 or MLord@clackamas.us

Hearings Officer Actions :

- Continued Hearing Until Click or tap to enter a date. at
- Closed Hearing:
 - Closed Record
 - Decision expected within 2 weeks.