



SLOPE FT/FT	MIN. ANCHOR SPACING CENTER TO CENTER
0.20 - 0.34	35'
0.35 - 0.50	25'
0.51+	15' OR CONC. ENCASEMENT

### ANCHOR WALL



CLACKAMAS COUNTY  
150 BEAVERCREEK ROAD  
OREGON CITY, OR 97045

APPROVAL DATE: 2011 SCALE: N.T.S.

### ANCHOR WALL

STANDARD DRAWING  
SAN-015