



GEORGE MARLTON, JD
PROCUREMENT DIVISION DIRECTOR

PROCUREMENT DIVISION
PUBLIC SERVICES BUILDING
2051 KAEN ROAD | OREGON CITY, OR 97045

REQUEST FOR PROPOSALS #2017-19
THICKENING AND DEWATERING POLYMER
ADDENDUM NUMBER 1
March 29, 2017

On March 15, 2017, Clackamas County ("County") on behalf of the Clackamas County Service District No. 1 and the Tri-City Service District, published Request for Proposals #2017-19 ("RFP"). The County has found that it is in its interest to amend the RFP through the issuance of this Addendum #1. Except as expressly amended below, all other terms and conditions of the original RFP and subsequent Addenda shall remain unchanged.

1. Section 3.3.1 Scope, Mandatory Requirements (B.) is hereby deleted in its entirety and replaced with:

B. The proposer must be able to supply approximately 10,500 lbs of dry polymer and 97,000 lbs wet polymer per year.

2. Section 3.3.2 Sample Testing Process, Baseline Cost is hereby modified as follows:

Baseline Cost:

Minimum Dewatering Performance (for the product to be found qualified):

- 1) % solids sludge (feed): 1.6% - 3.5%
- 2) % solids (cake - dewatered product): 21.0% (minimum)
- 3) % capture: **95%** (minimum)