



FIRE SPRINKLER AFFIDAVIT FOR ALTERATIONS OR TENANT IMPROVEMENTS

For 1 to 10 sprinkler heads, to be accompanied by a floor layout drawing showing the area of work within the building's structure

Building Permit No. _____

Project Name: _____ Occupancy: _____

Job Address: _____ Type of Construction: _____

Contractor: _____ Phone: _____

Proposed Quantities: Additional Heads _____ Altered Heads _____ Removed Heads _____

I, _____, Oregon Construction Contractors Board No. _____ certify that the following is true and reasonably defines the scope of work for this project:

- a) All work is limited to drops and armovers for a wet system (.10 density) located within a light-hazard occupancy.
- b) Positions of sprinkler heads relative to architectural features such as soffits, beams, partitions, walls, etc. complies with the current adopted edition of NFPA 13.
- c) The proposed work does not require hydraulic calculations.
- d) Only one sprinkler head will be installed from one drop (exception: up to two heads from one drop may be installed when each head is in a separate fire area).
- e) The area covered per sprinkler head is limited to the spacing requirements of NFPA 13.
- f) Tenant improvements in a new building shall be equipped with Quick Response heads, except where located within the same compartment as existing, standard response heads (see NFPA 13 for exceptions).
- g) The installation shall comply with the requirements of the current adopted edition of NFPA 13.
- h) Piping shall not be concealed until hangers and bracing are inspected.
- i) Final approval shall be subject to onsite tests and inspections.

In addition, I understand the following is required to be available on the jobsite for inspections and testing:

- **Job copy of required floor layout drawing, showing the area of work within the building's structure, and**
- **Manufacturer's product information (cutsheets) and installation instructions, and**
- **A copy of this document**

Signature: _____ Date: _____