

STREET & STORM DRAINAGE NOTES

1. STREET AND STORM DRAIN IMPROVEMENTS SHALL BE CONSTRUCTED IN ACCORDANCE WITH CLACKAMAS COUNTY ROADWAY STANDARDS AND THE APPROPRIATE SURFACE WATER DISTRICT. ALL STORM SEWER PIPES SHALL HAVE RUBBER GASKETS, WHICH SHALL PROVIDE A WATER TIGHT CONNECTION.
2. ALL TRENCH EXCAVATION SHALL CONFORM TO THE WATER ENVIRONMENT SERVICE PUBLICATION TITLED *CLACKAMAS COUNTY SERVICE DISTRICT NO. 1 – STANDARD SURFACE WATER SPECIFICATION*.
3. PIPE BEDDING AND PIPE ZONE SHALL CONFORM THE THE EXCAVATION AND BACKFILL DETAILS, AND SHALL BE 3/4”-0” CRUSHED ROCK.
4. COMPACTION SHALL BE PER ODOT/APWA STANDARD SPECIFICATIONS PART 3. CONTRACTOR TO DETERMINE TYPE OF EQUIPMENT AND THE METHOD USED TO ACHIEVE REQUIRED COMPACTION.
5. TRENCH BACKFILL OUTSIDE OF RIGHT-OF-WAYS OR PAVED AREAS MAY BE EXCAVATED TRENCH MATERIAL. TRENCH BACKFILL IN PAVED AREAS SHALL BE AN APPROVED GRANULAR MATERIAL.
6. MATERIAL IN SOFT SPOTS WITHIN THE ROADWAY SHALL BE REMOVED TO THE DEPTH REQUIRED TO PROVIDE A FIRM FOUNDATION AND SHALL BE REPLACED WITH 1 1/2”-0” CRUSHED ROCK. THE ENTIRE SUBGRADE SHALL BE THOROUGHLY COMPACTED TO 95% AASHTO T-99
7. CONTRACTOR SHALL NOTIFY THE ENGINEER WHEN SUBGRADE IS COMPLETE AND 24 HOURS PRIOR TO PLACEMENT OF BASE ROCK MATERIAL. CONTRACTOR SHALL ALSO NOTIFY THE ENGINEER 24 HOURS PRIOR TO FINAL PAVING FOR AN INSPECTION OF THE WORK. CLACKAMAS COUNTY REQUIRES A PROOF ROLL WITH A FULLY OADED 10-YARD DUMP TRUCK TO CHECK SUBGRADE COMPACTION PRIOR TO PLACEMENT OF ROCK SUBBASE AND AGAIN AT THE COMPLETION OF THE PLACEMENT OF THE BASE ROCK PRIOR TO PAVING THE FIRST LIFT OF ASPHALTIC CONCRETE.
8. PRIVATE STORM WATER DETENTION SYSTEMS ARE NOT PERMITTED IN THE PUBLIC RIGHT-OF-WAY

UTILITY NOTES

1. TRENCHES WITHIN THE RIGHTS-OF-WAY SHALL BE BACKFILLED WITH LOW STRENGTH CONTROLLED DENSITY FILL (CDF) WHEN:
 - TRENCHES LESS THAN 100’ WITHIN THE ROADWAY OF ALL ARTERIALS AND COLLECTOR CLASSIFIED ROADS;
 - THE AFFECTED ROADWAY SURFACE IS NEWER THAN FIVE (5) YEARS FROM THE TIME OF THE LAST OVERLAY, WITHOUT REGARD TO THE ROADWAY CLASSIFICATION;
 - DEEMED NECESSARY BY THE COUNTY ROAD OFFICIAL.

WHEN TRENCHES ARE EXEMPT FROM USE OF CDF THE ROADWAY TRENCH SHALL BE BACKFILLED WITH AN APPROVED GRANULAR MATERIAL CONFORMING TO ODOT/APWA CLASS B SPECIFICATIONS AND PER THE COUNTY CODE TITLE 7.03.100 THROUGH 7.03.230 AND SECTION 710 OF THE CLACKAMAS COUNTY ROADWAY STANDARDS.

2. TRENCHES OUTSIDE OF RIGHTS-OF-WAY MAY BE BACKFILLED IN ACCORDANCE WITH NATIVE MATERIAL AND COMPACTION SPECIFICATIONS FOR ODOT/APWA CLASS A BACKFILL.
3. COPIES OF THE CDF MATERIAL DELIVERY SLIPS SHALL BE SUBMITTED FOR COUNTY RECORDS. SUBMIT ____ COPIES TO THE COUNTY INSPECTOR.

REVISION	DATE	BY
REVISED	12/20	RN
REVISED	4/21	RM

DEPARTMENT OF TRANSPORTATION
AND DEVELOPMENT

150 BEAVERCREEK ROAD
OREGON CITY, OR 97045



APPROVAL DATE: 4/20/2021

SCALE: N.T.S.

STANDARD NOTES
STREET, STORM, AND UTILTIY

STANDARD
DRAWING

N300