



INVITATION TO BID #2019-06
Utilidor Piping and Conduit Extension Project (“BID”)
RESPONSE TO CLARIFYING QUESTIONS
March 21, 2019

Note that these are questions submitted by interested firms to the above referenced solicitation. The below answers are for clarification purposes only and in no way alter or amend the BID as published.

1. *Can you please confirm that all of the Aquatherm piping has to be installed by an Oregon Licensed Plumber?*

Answer: Due to the Aquatherm piping being mechanical plumbing, installation does not need to be an Oregon Licensed Plumber. Installers shall be trained and certified to install the pipe according to the manufacturer’s guidelines. See section 3.3 of the project specifications.

End of Clarifying Questions #3