



NOTES:

1. ALL PIPE AND FITTINGS SHALL BE ASTM D-3034, SDR 35.
2. ON LOTS WITH EXISTING HOMES, CONTRACTOR SHALL INSTALL APPROVED HUBS AND CAPS FLUSH WITH FINISHED GRADE.
3. CLEANOUTS SHALL NOT BE CONSTRUCTED SO THE CLEANOUT CAP WILL END UP IN SIDEWALKS, STEPS OR DRIVEWAYS.
4. EVERY PROPERTY SHALL HAVE A SEPARATE SERVICE LATERAL CONNECTED DIRECTLY TO THE MAINLINE, UNLESS OTHERWISE APPROVED BY THE DISTRICT. SHARED SERVICES ARE NOT ALLOWED.
5. THE SERVICE CONNECTION LOCATION SHALL GENERALLY BE LOCATED TEN FEET (10) OFFSET FROM THE PROPERTY LINE ON THE LOW SIDE OF LOT.
6. TEES FOR SERVICE CONNECTIONS SHALL BE LOCATED NO CLOSER THAN FIVE FEET (5) TO MANHOLES. SEPARATION BETWEEN WATER LINE, SANITARY SERVICE CONNECTION AND STORM SERVICE CONNECTION SHALL GENERALLY BE TEN FEET (10) WITH A MINIMUM OF FIVE FEET (5) .
7. ANY OTHER PROPOSED LOCATION SHALL BE AT THE DISCRETION OF THE DISTRICT ON CASE BY CASE BASIS.