



GEORGE MARLTON, JD
PROCUREMENT DIVISION DIRECTOR

PROCUREMENT DIVISION
PUBLIC SERVICES BUILDING
2051 KAEN ROAD | OREGON CITY, OR 97045

REQUEST FOR QUOTES #2017-49
Carbon Replacement for the Tri-City Wastewater Resource Recovery Facility
RESPONSE TO CLARIFYING QUESTIONS
June 28, 2017

Note that these are questions submitted by interested firms to the above referenced solicitation. The below answers are for clarification purposes only and in no way alter or amend the RFQ as published.

1. *Can we do the replacement on all filters over a 5-day period, Monday thru Friday?*

Answer: Replacing the carbon over the course of a 5-day period, M-F, is acceptable. We just need to make sure that only one tower is offline at a time.

2. *In the past replacements, was the media solidified or free flowing?*

Answer: The carbon was recently sampled. It was noted during the sampling that the material around the sampling ports was hard packed. We would not count on the material to be free-flowing. There is little information on the consistency of the carbon last time this work was performed.

End of Clarifying Questions