



**Department of Finance**

Public Services Building  
2051 Kaen Road, Suite 490 | Oregon City, OR 97045

April 20, 2023

BCC Agenda Date/Item: \_\_\_\_\_

Board of County Commissioners  
Clackamas County

**Adoption of a Board Order authorizing a Purchase Order to purchase (3) 750 Kw Generators and associated components through a cooperative contract from Cummins, Inc. Purchase order value is \$916,624.45. Funding is through budgeted County General Funds.**

<b>Previous Board Action/Review</b>	Briefed at Issues – April 18, 2023		
<b>Performance Clackamas</b>	Build (maintain) a strong infrastructure. Ensure safe, healthy and secure communities.		
<b>Counsel Review</b>	Yes	<b>Procurement Review</b>	Yes
<b>Contact Person</b>	Ralph C. Williams	<b>Contact Phone</b>	503-557-6421

**EXECUTIVE SUMMARY:** Aligning with the Red Soils Master Plan the Central Utility Plant (CUP) is in need of completing the full build-out that was part of the original design in 2007. This build-out is in support of the construction of the New Courthouse. Due to the extended lead times for product procurement, we are purchasing the components necessary in order to get them on order. This intent to purchase was advertised in accordance with ORS and LCRB Rules on March 10, 2023. There were no protests submitted in the allotted 7 day wait period.

**RECOMMENDATION:** Staff respectfully recommends that the Board approve and sign this purchase order request for Cummins for the purchase of generators and associated components.

Respectfully submitted,

*Elizabeth Comfort*

Elizabeth Comfort  
Finance Director

For Filing Use Only

**BEFORE THE BOARD OF COUNTY COMMISSIONERS  
OF CLACKAMAS COUNTY, STATE OF OREGON**

In the Matter of Approving  
Issuance of Purchase Order for  
Purchase of Three (3) DQFAA,  
Commercial Diesel Generator  
Sets, and Related Accessories



Board Order No. \_\_\_\_\_  
*Page 1 of 1*

**Whereas**, the Clackamas County Board of County Commissioners (the “Board”) has authority to sign all contracts and any amendments or renewals of the same;

**Whereas**, Oregon Revised Statutes (“ORS”) 279A.200-220 and Local Contact Review Board Rule C-046-0400 permit Clackamas County to purchase goods and services using cooperative contracts;

**Whereas**, Sourcewell, cooperative purchasing entity, established a cooperative contract, contract number 092222-CMM, with Cummins Inc. for the purchase of Commercial Diesel Generator Sets;

**Whereas**, the Clackamas County Finance Department, Facilities Management Division desires to utilize the aforementioned cooperative contract with Cummins, Inc. to purchase Three (3) DQFAA, Commercial Diesel Generator Sets, 750kW Standby 60Hz, and related accessories, as detailed in Cummins Quote Q-167712-20230330-1634, attached hereto as Exhibit A, for total of \$916,624.35;

**Whereas**, the Clackamas County Department of Finance requests authority to purchase the aforementioned goods and services by issuance of a purchase order (“PO”); and

**Whereas**, a PO is issued directly through the Clackamas County Department of Finance’s management software with no signature required or available;

**NOW THEREFORE, the Clackamas County Board of County Commissioners orders as follows:**

1. The requested purchase of the aforementioned goods and services from Cummins Inc., in the amount of \$916,624.35, is hereby approved;
2. The Clackamas County Department of Finance is hereby delegated limited authority to issue a PO to purchase the aforementioned equipment and services.

**DATED** this 20<sup>th</sup> day of April, 2023

**BOARD OF COUNTY COMMISSIONERS**

\_\_\_\_\_  
Chair

\_\_\_\_\_  
Recording Secretary



March 30, 2023

To

Clackamas County Dept. of Finance  
 1710 RED SOILS CT. STE 200  
 OREGON CITY Oregon 97045

Prepared by

Mark Wahlberg  
 503.307.7529  
 mark.wahlberg@cummins.com

We are pleased to provide you this quotation based on your inquiry.

Item	Description	Qty
1	<b>DQFAA, Commercial Diesel Generator Set, 750kW Standby 60Hz</b> U.S. EPA, Stationary Emergency Application 750DQFAA, Diesel Genset, 60Hz, 750kW Duty Rating - Standby Power (ESP) Emission Certification, EPA, Tier 2, NSPS CI Stationary Emergency Listing - UL 2200 Cert - Seismic, IBC2000, IBC2003, IBC2006, IBC2009, IBC2011 Voltage - 277/480, 3 Phase, Wye, 4 Wire Alternator - 60Hz, Wye, BR, 125/105C - Standby/Prime Steel Sound Attenuated Level 2 Enclosure, with Exhaust System Enclosure Color - Green, Steel Vibration Isolators - Earthquake Certified Cooling Air Outlet - Horizontal, Sound Attenuated Fuel Tank - Sub Base, 2000 Gallon, UL142 Compliant Compliance - Fuel Tank, Florida Listing, ULC - S601 - 07 Alarm - High Fuel Fill Fuel Water Separator Control Mounting - Left Facing Generator Set Control - PowerCommand 3.3, Paralleling with MLD LCD Control Display AmpSentry™ UL Listed Protective Relay Stop Switch - Emergency, Externally Mounted Signals - Auxiliary, 8 Inputs/8 Outputs Relays - Paralleling Circuit Breaker Control Control Display Language - English Circuit Breaker or Entrance Box or Terminal Box - Left Only EO - Circuit Breaker - 1200A, Left, 3P, UL/IEC 600V, 100% Circuit Breaker or Entrance Box or Terminal Box, Right-None Bottom Entry, Left Load Connections-None Indication - Ground Fault, 3 - Pole Transfer Switch Engine Air Cleaner - Normal Duty Engine Cooling - Radiator, Enhanced High Ambient Air Temperature, Ship Fitted Shutdown - Low Coolant Level Sight Glass - Coolant Level Coolant Heater - 208/240/480 Volts AC, 40F Minimum Ambient Temperature Oil Sampling Valve Genset Warranty - 2 Years Base Literature - English	3
2	<b>Sourcewell Pricing</b>	1
3	<b>2" Atmospheric Vent Pipe</b>	3
4	<b>BATTERY GROUP 34: C34-HC</b>	12
5	<b>A064W844, Cable Kit, DQFAA-D (Enclosed Generator)</b>	3
6	<b>Battery Charger-10Amp, 120/208/240VAC, 12/24V, 50/60Hz</b>	3

7	Cummins 3000A Switchboard, 4000A Bus, 277/480V, 3-Ph, Nema 1	1
8	3000A SER ATS, 480V, 3-Ph, 3-P, Nema 1	1
9	3000A Load Bank Connection Cabinet, 480V, 3-Ph, 3R, Wall Mount	1
10	No-Spec Startup Service and System Testing	3

**TOTAL: \$ 916,624.35**

Quote value does not include any tax.

**EXCEPTIONS AND CLARIFICATIONS:**

The basis of this quote is configured around email request, no specs or one-line provided.  
 This is a basic configuration, the contractor to confirm the equipment BOM will meet the project requirements.

**NOTES:**

Quote is valid for 30 days.

**LEAD TIME:**

**Current Factory Lead Time:** 79-81 weeks after submittal approval  
**Submittal Lead Time:** 2 weeks after receipt of purchase order



Please feel free to contact me if you require any additional information; or if you have any further questions or concerns that I may be of assistance with.

Thank you for choosing Cummins.

**Submitted by:**

**Mark Wahlberg, Territory Manager, Power Generation, Pacific Region**  
[mark.wahlberg@cummins.com](mailto:mark.wahlberg@cummins.com)  
503.307.7529

**SUBMITTALS.** An order for the equipment covered by this quotation will be accepted on a hold for release basis. Your order will not be released and scheduled for production until written approval to proceed is received in our office. Such submittal approval shall constitute acceptance of the terms and conditions of this quotation unless the parties otherwise agree in writing.

**THERE ARE ADDITIONAL CONTRACT TERMS AND CONDITIONS ATTACHED TO THIS QUOTATION, INCLUDING LIMITATIONS OF WARRANTIES AND LIABILITIES, WHICH ARE EXPRESSLY INCORPORATED HEREIN. BY ACCEPTING THIS QUOTATION, CUSTOMER ACKNOWLEDGES THAT THE CONTRACT TERMS AND CONDITIONS HAVE BEEN READ, FULLY UNDERSTOOD AND ACCEPTED.**

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Printed Name & Title

\_\_\_\_\_  
Purchase Order No

<Rest of the page is intentionally left blank>