



INVITATION TO BID #2017-74  
SE 115<sup>th</sup> Avenue Utility Extension  
Project ADDENDUM NUMBER 3  
September 14, 2017

On August 30, 2017, Clackamas County ("County") published Invitation to Bid #2017-74 ("BID"). The County has found that it is in its interest to amend the BID through the issuance of this Addendum #3. Except as expressly amended below, all other terms and conditions of the original BID and subsequent Addenda shall remain unchanged.

1. Clarification: Pay Item 5 – 00290 – Pollution Control Plan is for furnishing a Pollution Control Plan in accordance with the requirements of Section **00290 – POLLUTION CONTROL**.
2. Modify Revision to Standard Specification **SECTION 00290 – ENVIRONMENTAL PROTECTION 00290.90 Payment** as follows:

The accepted quantities for work performed under this Section will be paid for at the Contract Lump Sum amount for the item "Pollution Control Plan". Full payment will be made when the Pollution Control Plan is approved and fully implemented.

3. Clarification: The entire length of new water main shall be mechanically restrained (per Plans Sheet 8 – Keyed Note 4). Plans - Sheet 8 – Keyed Note 2 notes 'mechanically restrain 65 feet'. This note is redundant with the requirement of full pipe restraint and can be deleted.

---

End of Addendum #3