



NOTES

1. SPECIFICATIONS FOR CONCRETE AND MISCELLANEOUS MATERIALS USED IN CONSTRUCTION SHALL CONFORM TO CURRENT OREGON STANDARD SPECIFICATIONS FOR CONSTRUCTION.
2. CONCRETE SHALL HAVE A MINIMUM COMPRESSIVE STRENGTH OF 3300 PSI IN 28 DAYS, 2" TO 4" SLUMP.
3. WEEP HOLES ARE NOT ALLOWED.
4. EXPANSION JOINTS, MAX. 45' SPACING AND AT BEGINNING AND END OF CURVES OR AS DIRECTED.
5. CONTRACTION JOINTS, MAX. 12' SPACING AND AT LOCATIONS AS DIRECTED.
6. SEE NOTES ON DETAIL S100.

H:\survey\2019\Design Drawings\ S180.dwg

REVISION	DATE	BY	DEPARTMENT OF TRANSPORTATION AND DEVELOPMENT	APPROVAL DATE:	SCALE: N.T.S.	STANDARD DRAWING
EDIT NOTE 1	12/12	RN				
	11/19	BP				

150 BEAVERCREEK ROAD
OREGON CITY, OR 97045



MOUNTABLE CURB

S180