



#### NOTES

1. SPECIFICATIONS FOR CONCRETE AND MISCELLANEOUS MATERIALS USED IN CONSTRUCTION SHALL CONFORM TO CURRENT OREGON STANDARD SPECIFICATIONS FOR CONSTRUCTION.
2. CONCRETE SHALL HAVE A MINIMUM COMPRESSIVE STRENGTH OF 3300 PSI IN 28 DAYS, 2" TO 4" SLUMP.
3. 4" PLASTIC PIPE SHALL HAVE A BELL OR A 3" EXTENSION, FOR FUTURE HOOK-UP.
4. EXPANSION JOINTS, MAX. 45' SPACING AND AT BEGINNING AND END OF CURVES OR AS DIRECTED.
5. CONTRACTION JOINTS, MAX. 15' SPACING AND AT LOCATIONS AS DIRECTED.
6. USE FROM PC TO PT AT PUBLIC INTERSECTIONS INSIDE THE UGB AND UNINCORPORATED COMMUNITIES. ALSO USE WHEN THE GUTTER SLOPE OR CURB LINE IS LESS THAN 1% ON ALL PUBLIC ROADS.
7. SEE NOTES ON DETAIL S100.

REVISION	DATE	BY	DEPARTMENT OF TRANSPORTATION AND DEVELOPMENT	APPROVAL DATE: 01/31/2020	SCALE: N.T.S.	STANDARD DRAWING
EDIT NOTE 1	12/12	RN				
REVISED	11/19	AAR				

150 BEAVERCREEK ROAD  
OREGON CITY, OR 97045



STANDARD CURB AND GUTTER

S150