



INVITATION TO BID #2018-81  
COLLECTION SYSTEM REHAB-  
SANITARY SEWER MAINLINE ("BID")  
ADDENDUM NUMBER 1  
October 9, 2018

On September 27, 2018, Clackamas County ("County") published Invitation to Bid #2018-81 ("BID"). The County has found that it is in its interest to amend the BID through the issuance of this Addendum #1. Except as expressly amended below, all other terms and conditions of the original BID shall remain unchanged.

**1. Remove and replace Section 01010, 1.02.B.4 with:**

Contractor's Normal work hours shall be limited to between 7:00 a.m. to 7:00 p.m., Monday through Friday excepting Owner legal holidays. Night hours will be necessary for work in the Sunnybrook/Sunnyside and Evelyn Street Area during off-peak usage. Saturday hours will be necessary for work on SE 130<sup>th</sup> Avenue when Pacific Seafoods is not operating the facility.

**2. Section 02775, Paragraph 1.06.A, shall be revised to read:**

The Manufacturer or Assembler shall send a representative familiar with CIPP processes for a single visit to be on site for installation of the first run between two manholes.

**3. Section 02775, Paragraph 3.02.F, shall be revised to read:**

Temperature and curing data shall be monitored and recorded by the Contractor throughout the process in accordance with manufacturer's recommendation. This shall specifically include data from all thermocouples for incoming and outgoing water or steam supply and at the remote manhole. Submit information for each lining to the Engineer.

**4. Section 02775, Remove in its entirety Paragraph 3.04.A.4.**

**5. Section 02775, Paragraph 2.01.G shall be supplemented by the following:**

Minimum thickness of UV liner, if approved shall be 3 mm for all installations with final thickness as stamped by the engineer.

---

End of Addendum #1